

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

MARSHA L. BROWN  
PRESIDENT

VAN AMBATIELOS  
VICE-PRESIDENT

VICTOR H. CUEVAS  
HELENA JUBANY  
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA  
MAYOR

DEPARTMENT OF  
BUILDING AND SAFETY  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.  
GENERAL MANAGER

RAYMOND CHAN  
EXECUTIVE OFFICER

Aircooler Corporation  
1751 Floradale Avenue  
South El Monte, CA 91733

Attn: William Der  
(626) 454-3389

RESEARCH REPORT: RR 25747  
(CSI #13030)

Expires: May 1, 2011  
Issued Date: May 1, 2009  
Code: 2008 LABC

**GENERAL APPROVAL** - Aircooler Corporation Refrigeration Panels for Walk-In Coolers and Freezers.

## DETAILS

The panels are fabricated in thickness of 3-1/2", 4, and 5". The core material is Dow Chemical Voracor CE157 and CE1004. The panel facings are 26 gauge galvanized metal ASTM A-653. The perimeters of the panels are foamed with a kiln-dried Douglas wooden or high-density foam. The panels are joined together with cam-activated locking devices with a maximum spacing of 48".

Frame spread and smoke development ratings for the panel per ASTM E84 are 20 and 300 respectively, and for foam (tested alone) and 15 and 250 respectively. Density of the foam is 2.25 pcf

The panels are approved as structural wall and ceiling panel for use in interior for class 1 rated walk-in coolers and freezers. The allowable loads for exterior panels subject to wind loads shall be evaluated on a case by case basis.

### **Aircooler Corporation freestanding walk-in coolers and freezers constructed of panels described above are approved subject to the following conditions:**

1. Use of the panels shall be limited to locations where combustible construction is permitted by the 2008 Los Angeles City Building Code.
2. The panels shall be fabricated in a shop of a licensed fabricator approved by the Los Angeles City Building & Safety Department. Fabrication in unlicensed shops will invalidate this approval.

RR 25747  
Page 1 of 5

Aircooler Corporation

Re: Aircooler Corporation Refrigeration Panels for Walk-In Coolers and Freezers.

3. Complete plans and calculations, signed and stamped by a civil or structural engineer or architect registered in the State of California, shall be submitted to the structural plan check engineer for approval of each job.
4. The allowable loads for outdoor panels subject to wind loads shall be evaluated on a case by case basis.
5. The panel foam shall be separated from the room in which it is located and from the interior of the cooler and freezer by ½-inch thick gypsum wallboard or other approved thermal barrier material having an index of 15 when tested in accordance with UBC Standard No. 26-2. Sections 2603.4.1.2 and 2603.4.1.3 of the 2008 Los Angeles City Building Code may be utilized where applicable.
6. A separate approval from the Electrical Testing Laboratory shall be required for electrical installations within the panels. Plumbing and waste line may extend at right angle through the wall panels but are not permitted vertically within the core.
7. A factor of safety of at least 2.5 is required. Design of building utilizing the panels shall be in accordance with the requirements of the 2008 Los Angeles City Building Code and the design data specified:

A. Maximum Allowable Loads for Ceiling Panels

Panel Span (in)	Panel Thickness (in.)					
	t = 3.5 in. Wood frame	t = 3.5 in. Foam frame	t = 4 in. Wood frame	t=4 in. Foam frame	t = 5 in. Wood frame	t = 5 in. Foam frame
10'	46*	43	70*	51	79*	66*
12'	42	31	45*	37	66	51
14'	27	22	35	28	53	38
16'	20	17	27	21	45	30
18'	16	13	20	16	37	23
20'	12	10	16	13	23	18
22'	10	8	12	10	19	15
24'	8	6	10	8	16	12
26'	7	5	8	7	12	10
28'	5	4	7	6	10	8

Aircooler Corporation

Re: Aircooler Corporation Refrigeration Panels for Walk-In Coolers and Freezers.

30'	4	3	6	5	8	7
32'	-	-	-	-	7	6

\* Computed load limited by shear stress

B. Allowable wall panel loads

	Panel Thickness					
	3.5-in.		4.0-in.		5.0-in.	
	Wood Frame	Foam Frame	Wood Frame	Foam Frame	Wood Frame	Foam Frame
10	720	690	944	700	1121	705
15	612	511	760	636	914	678
20	398	328	508	421	752	627
25	200	210	341	277	526	338
30	-	-	218	180	356	297

Note: The allowable loads for outdoor panels subject to wind loads should be evaluated on a case-by-case basis.

C. Maximum allowable height of non-bearing wall panel

Panel thickness	Wood Frame (ft.)	Foam Frame (ft.)
3 ½"	28	26
4"	32	30
5"	34	32

D. Maximum Allowable Loads for Kason Type 1156B Cam-Locking Devices:

Connection	Shear (lbs)		Tension (lbs)	
	Wood Frame	Foam Frame	Wood Frame	Foam Frame
Panel to Panel	449	172	179	123
Ceiling to Panel	328	139	245	108

Aircooler Corporation

Re: Aircooler Corporation Refrigeration Panels for Walk-In Coolers and Freezers.

- E. Base Connections: Wall panels are attached to the floor with a 16-gauge 1-1/2"x1-1/2" steel angle. The maximum allowable shear and tension loads are as follows:

Type	Shear (lbs)	Tension (lbs)
Wood Panel	492	230
Foam Panel	479	214

8. Locations of connectors must be detailed on approved plans, the spacing of connections shall be calculated for each job but not less than two per width of panel (Width of panel = 47").
9. An approved fire retardant roof covering (class "A" or "B") shall be place over the panel when used as exterior roof panels.
10. Each panel shall be stamped with the company name on the panel edge using an indelible ink, as shown on attachment 4.
11. All design values and methods not included in this report shall be in accordance with requirements of the 2008 Angeles City Building Code.

Aircooler Corporation

Re: Aircooler Corporation Refrigeration Panels for Walk-In Coolers and Freezers.

## **DISCUSSION**

The approval is based on tests on the foam per requirements of Sec. 2603 of the 2008 Los Angeles City Building Code, tests conducted in accordance with ASTM E-84 on the finished panels, and load tests conducted in accordance with ASTM E-72.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

YEUAN CHOU, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone - 213-202-9812  
Fax - 213-202-9942

BG:elcm  
RR25747/MSWord2003  
R04/21/2009  
5D2/2603

Attachment: Panel Connection Details/Installation/Panel Identification (4 Pages).